

	項 目	単位	数 量	計 算 式							
				コメント	Xm	Ym		定数	倍数		
1	直接仮設工事										
	養生	外壁改修	m2	316.09							
	整理清掃後片付			5.46	北面	2.73			2.00	1.00	
				21.74		10.87			2.00	1.00	
				7.33		3.67			2.00	1.00	
				60.40		30.20			2.00	1.00	
				7.33		3.67			2.00	1.00	
				21.74		10.87			2.00	1.00	
				11.30	東面	5.65			2.00	1.00	
				5.46		2.73			2.00	1.00	
				19.80		9.90			2.00	1.00	
				114.80	南面	57.40			2.00	1.00	
				19.80	西面	9.90			2.00	1.00	
				11.30		5.65			2.00	1.00	
				3.51	中庭	1.76			2.00	1.00	
				6.12		3.06			2.00	1.00	
		枠組本足場	建枠900*1700	m2	1,634.89						
		手すり先行方式	布枠500+240		28.26	北面	2.73	10.35			1.00
			12m未満		112.50		10.87	10.35			1.00
				37.93		3.67	10.35			1.00	
				312.57		30.20	10.35			1.00	
				37.93		3.67	10.35			1.00	
				112.50		10.87	10.35			1.00	
				58.48	東面	5.65	10.35			1.00	
				28.26		2.73	10.35			1.00	
				102.47		9.90	10.35			1.00	
				594.09	南面	57.40	10.35			1.00	
				102.47	西面	9.90	10.35			1.00	
				58.48		5.65	10.35			1.00	
				26.15	中庭	1.76	7.45			2.00	
				22.80		3.06	7.45			1.00	
		養生シート	防災Ⅰ類	m2	1,634.89						
					1,634.89	枠組本足場	1634.89				1.00
	安全手すり	枠組本足場用	m	158.06							
	手すり先行方式			2.73	北面	2.73				1.00	
				10.87		10.87				1.00	
				3.67		3.67				1.00	
				30.20		30.20				1.00	
				3.67		3.67				1.00	
				10.87		10.87				1.00	
				5.65	東面	5.65				1.00	
				2.73		2.73				1.00	
				9.90		9.90				1.00	
				57.40	南面	57.40				1.00	
				9.90	西面	9.90				1.00	
				5.65		5.65				1.00	
				1.76	中庭	1.76				1.00	
				3.06		3.06				1.00	
		内部仕上足場	脚立足場	m2	402.05						
		階高4.0m以下			203.85	外装薄塗材Si吹付面（階段室以外）	203.85	1.00			1.00
					67.47	ケイカルEP面	67.47	1.00			1.00
				11.06	ケイカル外装薄塗材Si面	11.06	1.00			1.00	
				7.56	開放廊下 1階 天井	7.56	1.00			1.00	
				56.98		56.98	1.00			1.00	
				11.56		11.56	1.00			1.00	
				0.47	脆弱箇所②	0.47	1.00			1.00	
				0.12	③	0.12	1.00			1.00	
				0.64	④	0.16	1.00			4.00	
				0.40	⑤	0.40	1.00			1.00	
				18.04	屋外物置前 天井	9.02	1.00			2.00	
				▲ 3.24	AW-11	0.90	1.80			▲ 2.00	
				0.94	A-11 ハコニー梁 1階	0.11	0.85			10.00	
				6.40		3.94	0.33			5.00	
				0.94	A-11 ハコニー梁 2階	0.11	0.85			10.00	
				6.40		3.94	0.33			5.00	
				2.58	A-11 2階廊下梁	1.27	0.34			6.00	
				1.32		0.30	2.20			2.00	
				2.42		0.55	2.20			2.00	
				2.37		0.79	1.00			3.00	
				0.68		0.17	1.00			4.00	
				1.50		0.75	1.00			2.00	
				1.36		0.68	1.00			2.00	
				0.23		0.23	1.00			1.00	

	項 目	単位	数 量	計 算 式						定数	倍数	
				コmnt	Xm	Ym						
	内部階段仕上足場	m2	75.74									
			16.53	A-19、A-09 1、2階階段室天井	2.76	1.50					4.00	
			5.97		1.81	1.65					2.00	
			0.98		1.64	0.30					2.00	
			5.28		1.38	1.92					2.00	
			8.11		2.70	1.50					2.00	
			1.48		0.21	3.53					2.00	
			18.61	A-11 3階階段室天井	18.61	1.00					1.00	
			18.78		18.78	1.00					1.00	
											2.00	
2	内外壁改修工事											
外壁	外壁事前調査	m3	2,291.30									
			32.08	基礎巾木	32.08						1.00	
			11.99	梁笠木	11.99						1.00	
			720.58	打放し面	720.58						1.00	
			572.84	タイル面	572.84						1.00	
			631.40	吹付タイル面	631.40						1.00	
			279.59	外装薄塗材Si面	279.59						1.00	
			42.82	巾木	42.82						1.00	
外壁	クラック補修	m	1.60	躯体改修内容表より								
	Uカットシール充填工法		0.95	南面	0.95						1.00	
			0.65	北面	0.65						1.00	
外壁	タイル面浮き補修	m2	0.16									
	アンカーボルト全面ボキシ樹脂注入		0.16	躯体改修内容表より	0.16						1.00	
	高圧水洗	m3	1,373.35									
			32.08	外壁 基礎巾木	32.08						1.00	
			11.99	外壁 梁笠木	11.99						1.00	
			720.58	外壁 打放し面	720.58						1.00	
			572.84	外壁 タイル面	572.84						1.00	
			7.34	外壁 吹付タイル面	7.34						1.00	
			28.52	外部 外装薄塗材Si面	28.52							
	超耐久・低汚染水性ふっ素樹脂クリアー工法仕	m2	34.48									
	下地調整材C-2		32.08	基礎巾木	32.08	1.00					1.00	
			2.40	梁笠木（全体の20%）	2.40	1.00					1.00	
	打放しファシジョンロー工法	m2	720.58									
	下地調整材C-2		366.33		366.33	1.00					1.00	
			354.25		354.25	1.00					1.00	
	超汚染・超耐久型2液水性ふっ素樹脂塗料	m2	35.59									
	吹付タイル		15.35	開放廊下（全体の4%）	15.35	1.00					1.00	
			0.90	階段通路（全体の1%）	0.90	1.00					1.00	
			12.00	階段室（全体の8%）	12.00	1.00					1.00	
			7.34	バルコニー	7.34	1.00					1.00	
	水洗い工法	外壁	m3	624.06								
			383.84	吹付タイル面（開放廊下）	383.84						1.00	
			90.18	吹付タイル面（階段通路）	90.18						1.00	
			150.04	吹付タイル面（階段室）	150.04						1.00	
	水洗い工法	天井	m3	251.07								
			251.07	開放廊下、階段室天井	251.07						1.00	
	外装薄塗材Si吹付	リシン	m2	279.59								
	下地調整C-2共		28.52	バルコニー	28.52	1.00					1.00	
			175.33	廊下	175.33	1.00					1.00	
			75.74	階段室	75.74	1.00					1.00	
	超耐久・低汚染水性ふっ素樹脂クリアー工法仕	m2	2.40									
	全体数量の20% 梁笠木		2.40		11.99	0.20					1.00	
集計	超汚染・超耐久型2液水性ふっ素樹脂塗料	m2	15.35	吹付タイル								
	全体数量の4% 開放廊下		15.35		383.84	0.04					1.00	
集計	超汚染・超耐久型2液水性ふっ素樹脂塗料	m2	0.90	吹付タイル								
	全体数量の1% 階段通路		0.90		90.18	0.01					1.00	
集計	超汚染・超耐久型2液水性ふっ素樹脂塗料	m2	12.00	吹付タイル								
	全体数量の8% 階段室		12.00		150.04	0.08					1.00	
外壁	下地調整材C-2	基礎巾木	m2	32.08								
	超耐久・低汚染水性ふっ素樹脂クリアー工法仕上		2.95	A-07南面	3.28	0.45					2.00	
	高圧水洗		9.72		4.32	0.45					5.00	
			7.16		7.96	0.45					2.00	
			2.77		6.16	0.45					1.00	
			3.18		7.06	0.45					1.00	
			6.30		1.40	0.45					10.00	
				北東西面無								

	項 目	単位	数 量	計 算 式						
				コmnt	Xm	Ym		定数	倍数	
外壁	下地調整材C-2 梁笠木	m2	11.99							
	超耐久・低汚染水性ふっ素樹脂クリアー工法仕上		2.79	2、3階南面 梁笠木	2.18	0.16			8.00	
	高压水洗		5.05		3.16	0.16			10.00	
			2.16		2.26	0.16			6.00	
			0.70	2階東西面 梁笠木	2.20	0.16			2.00	
			1.29		4.04	0.16			2.00	
外壁	高压水洗 タイル面	m2	572.84							
			43.45	A-14 西面	7.90	5.50			1.00	
			0.65		0.65	1.00			1.00	
			8.38	半円	8.38	1.00			1.00	
			2.50	柱型	2.50	0.10			10.00	
			▲ 2.81	AW-6	0.60	1.17			▲ 4.00	
			33.90		5.65	6.00			1.00	
			▲ 1.90	開口	1.27	1.50			▲ 1.00	
			▲ 2.29		1.27	1.80			▲ 1.00	
			77.37	A-12 北面	6.97	5.55			2.00	
			▲ 8.16	AW-7	1.70	1.20			▲ 4.00	
			▲ 8.28	AW-10	1.09	1.90			▲ 4.00	
			▲ 5.15	開口	1.43	1.80			▲ 2.00	
			▲ 4.29		1.43	1.50			▲ 2.00	
			2.00	柱型	0.10	2.50			8.00	
			6.60		0.55	6.00			2.00	
			3.53		3.53	0.50			2.00	
			199.80		33.30	6.00			1.00	
			▲ 9.05	開口	4.77	1.90			▲ 1.00	
			▲ 7.15		4.77	1.50			▲ 1.00	
			▲ 10.32		5.43	1.90			▲ 1.00	
			▲ 8.15		5.43	1.50			▲ 1.00	
			▲ 6.17		3.63	0.85			▲ 2.00	
			▲ 17.92		9.43	1.90			▲ 1.00	
			▲ 14.15		9.43	1.50			▲ 1.00	
			▲ 3.91		2.30	0.85			▲ 2.00	
			▲ 9.05		4.77	1.90			▲ 1.00	
			▲ 7.15		4.77	1.50			▲ 1.00	
			▲ 12.43	AW10	1.09	1.90			▲ 6.00	
			43.45	A-14 東面	7.90	5.50			1.00	
			0.65		0.65	1.00			1.00	
			8.38	半円	8.38	1.00			1.00	
			2.50	柱型	2.50	0.10			10.00	
			▲ 2.81	AW-6	0.60	1.17			▲ 4.00	
			33.90		5.65	6.00			1.00	
			▲ 1.90	開口	1.27	1.50			▲ 1.00	
			▲ 2.29		1.27	1.80			▲ 1.00	
			332.40	A-12 南面	55.40	6.00			1.00	
			10.00	柱型	2.50	0.10			40.00	
			▲ 51.81	AW-2、2A	2.70	1.92			▲ 10.00	
			▲ 19.55	AW-4A	1.70	1.15			▲ 10.00	
			▲ 60.16	AW-3A	3.14	1.92			▲ 10.00	
			64.40	パドルコーナー	1.40	2.30			20.00	
			▲ 9.78	AW5A	0.85	1.15			▲ 10.00	
			▲ 14.39	AD5	0.75	1.92			▲ 10.00	
外壁	下地調整材C-2 打放し	m2	366.33							
	打放しファンデーションローラー工法		23.70	A-07、14 西面	7.90	3.00			1.00	
	高压水洗		1.00	柱型	0.10	2.50			4.00	
			0.22	梁型	0.10	2.21			1.00	
			0.40		0.10	4.05			1.00	
			10.96		4.39	2.50			1.00	
			0.46	柱型	0.19	2.50			1.00	
			2.68		2.68	1.00			1.00	
			0.18		0.19	0.95			1.00	
			3.91	アール	4.11	0.95			1.00	
			▲ 1.40	AW-6	0.60	1.17			▲ 2.00	
			3.80	A-07、12北面	0.55	3.45			2.00	
			8.60		1.72	2.50			2.00	
			3.30		0.55	3.00			2.00	
			3.30	柱型	0.55	3.00			2.00	
			2.19		0.37	3.00			2.00	
			3.87	アール	4.18	0.93			1.00	
			4.87		3.53	0.69			2.00	
			3.30		0.55	3.00			2.00	
			1.66	柱型	0.18	2.31			4.00	
			23.79	階段横壁 (A-07)	3.97	3.00			2.00	
			▲ 3.60	SD-5	0.90	2.00			▲ 2.00	
			▲ 0.41	AG-1	0.45	0.45			▲ 2.00	
			13.13	A-12 北面	6.57	1.00			2.00	
			14.13		1.57	3.00			3.00	
			▲ 6.21	AW-10	1.09	1.90			▲ 3.00	
			3.93		1.97	1.00			2.00	
			4.37		4.37	1.00			1.00	
			2.77		2.77	1.00			1.00	
			9.18		3.28	2.80			1.00	
			0.50	柱型	0.10	2.50			2.00	

項 目			単位	数 量	計 算 式				定数	倍数	
					コmnt	Xm	Ym				
				0.22	梁型	0.10	2.18			1.00	
				4.03		4.24	0.95			1.00	
				23.70	A-14東面	7.90	3.00			1.00	
				1.00	柱型	0.10	2.50			4.00	
				0.22	梁型	0.10	2.21			1.00	
				0.40		0.10	4.05			1.00	
				12.64		3.67	3.45			1.00	
				2.16		0.72	3.00			1.00	
				0.64		0.19	3.45			1.00	
				0.88		0.88	1.00			1.00	
				166.20	A-12南面	55.40	3.00			1.00	
				▲ 1.96	AW-4A	1.70	1.15			▲ 1.00	
				▲ 27.00	AW-1	2.70	2.00			▲ 5.00	
				▲ 30.08	AW-3	3.14	1.92			▲ 5.00	
				▲ 7.82	AW-4	1.70	1.15			▲ 4.00	
				0.72	梁型	2.18	0.17			2.00	
				3.25		3.94	0.17			5.00	
				2.60		3.16	0.17			5.00	
				1.12		2.26	0.17			3.00	
				34.30	A-07 テラス内	1.40	2.45			10.00	
				52.92		4.32	2.45			5.00	
				▲ 4.89	AW-5	0.85	1.15			▲ 5.00	
				▲ 7.50	AD-4	0.75	2.00			▲ 5.00	
	外部	下地調整材C-2	打放し	m2	354.25						
		打放しファンデーションロー	工法		42.30	A-07、A-19屋外物置前	3.59	2.95			4.00
		高圧水洗			1.80		0.90	0.50			4.00
					3.60		1.80	0.50			4.00
					8.67		1.45	2.99			2.00
					▲ 18.00	AD-2	0.90	2.00			▲ 10.00
					1.87	梁型	2.88	0.33			2.00
				0.64		1.43	0.23			2.00	
				0.94	A-11 テラス梁型 1階	0.11	0.85			10.00	
				6.40		3.94	0.33			5.00	
				1.48	A-07開放廊下 1階南面 壁	0.28	2.65			2.00	
				22.11		1.89	2.34			5.00	
				10.87		2.05	2.65			2.00	
				3.18		0.30	2.65			4.00	
				31.16		5.88	2.65			2.00	
				2.92		0.55	2.65			2.00	
				12.45		5.06	2.46			1.00	
				16.38		6.18	2.65			1.00	
				7.76		2.93	2.65			1.00	
				9.36	玄関前	0.80	2.34			5.00	
				8.19		0.70	2.34			5.00	
				4.64	柱型	0.35	2.65			5.00	
				5.57	カウンター部	0.35	2.65			6.00	
				4.59	屋外物置前	0.98	2.34			2.00	
				1.17		0.25	2.34			2.00	
				4.37		0.55	2.65			3.00	
				1.40		0.53	2.65			1.00	
				1.59		0.60	2.65			1.00	
				▲ 19.85	AD1	1.89	2.10			▲ 5.00	
				▲ 1.01	AW8	0.45	0.45			▲ 5.00	
				▲ 2.88	AW9	0.60	0.60			▲ 8.00	
				▲ 0.72	AW9A	0.60	0.60			▲ 2.00	
				▲ 8.24	SD4	1.53	1.80			▲ 3.00	
				▲ 6.09	SD3	1.25	2.44			▲ 2.00	
				▲ 8.50	AD3	0.85	2.00			▲ 5.00	
				▲ 1.43	AW7B	1.50	0.95			▲ 1.00	
				▲ 2.04	AW7A	1.70	1.20			▲ 1.00	
				7.69	北面	1.45	2.65			2.00	
				6.65		1.26	2.65			2.00	
				1.59		0.30	2.65			2.00	
				7.95		1.50	2.65			2.00	
				3.18		0.30	2.65			4.00	
				11.82		6.57	0.90			2.00	
				12.48		1.57	2.65			3.00	
				3.81		2.12	0.90			2.00	
				8.49		9.43	0.90			1.00	
				2.39		0.30	2.65			3.00	
				4.37		0.55	2.65			3.00	
				1.76	自転車置場前	0.98	0.90			2.00	
				▲ 6.21	AW10	1.09	1.90			▲ 3.00	
				1.96	A-127ルミバ 補開口	2.30	0.85			1.00	
				1.72	A-11梁型	1.27	0.34			4.00	
				1.03		1.52	0.34			2.00	
				7.56	開放廊下 1階 天井	7.56	1.00			1.00	
				56.98		56.98	1.00			1.00	

	項 目	単位	数 量	計 算 式				定数	倍数	
				コメント	Xm	Ym				
			11.56		11.56	1.00			1.00	
			0.47	脆弱箇所②	0.47	1.00			1.00	
			0.12	③	0.12	1.00			1.00	
			0.64	④	0.16	1.00			4.00	
			0.40	⑤	0.40	1.00			1.00	
			18.04	屋外物置前 天井	9.02	1.00			2.00	
			▲ 3.24	AW-11	0.90	1.80			▲ 2.00	
			0.94	A-11 ハルコニー梁 1階	0.11	0.85			10.00	
			6.40		3.94	0.33			5.00	
			12.36	自転車置場	3.09	1.00			4.00	
			26.40		6.60	1.00			4.00	
			▲ 3.60	開口	0.18	1.00			▲ 20.00	
			1.62	足洗い場	0.90	0.90			2.00	
			0.27		0.15	0.90			2.00	
	水洗い工法	吹付タイル	m2	90.18						
		超汚染・超耐久型2液水性ふっ素樹脂塗料		56.13	1階南側	3.53	2.65			6.00
		階段通路		3.71	カウンター部	0.35	2.65			4.00
			▲ 5.49	SD4	1.53	1.80			▲ 2.00	
			1.65	梁型	1.27	0.33			4.00	
			18.71	2階 南側	3.53	2.65			2.00	
			3.71	カウンター部	0.35	2.65			4.00	
			▲ 5.49	SD4	1.53	1.80			▲ 2.00	
			1.64	梁型	1.27	0.33			4.00	
			16.24	3階 南側	3.53	2.30			2.00	
		3.22	カウンター部	0.35	2.30			4.00		
		▲ 5.49	SD4	1.53	1.80			▲ 2.00		
		1.64	梁型	1.27	0.33			4.00		
外部	下地調整材C-2	吹付タイル	m2	7.34						
	超汚染・超耐久型2液水性ふっ素樹脂塗料		0.94	A-11 ハルコニー梁型 2階	0.11	0.85			10.00	
	高圧水洗工法		6.40		3.94	0.33			5.00	
外部	水洗い工法	吹付タイル	m2	383.84						
	超汚染・超耐久型2液水性ふっ素樹脂塗料		1.48	A-08 2階南面 廊下壁	0.28	2.65			2.00	
	開放廊下		22.11		1.89	2.34			5.00	
		10.87		2.05	2.65			2.00		
		3.18		0.30	2.65			4.00		
		31.16		5.88	2.65			2.00		
		2.92		0.55	2.65			2.00		
		15.18		5.06	3.00			1.00		
		16.38		6.18	2.65			1.00		
		7.76		2.93	2.65			1.00		
		9.36	玄関前	0.80	2.34			5.00		
		8.19		0.70	2.34			5.00		
		4.64	柱型	0.35	2.65			5.00		
		5.57	カウンター部	0.35	2.65			6.00		
		16.53	コモンスペース	2.76	3.00			2.00		
		1.50		0.25	3.00			2.00		
		4.37	柱型	0.55	2.65			3.00		
		▲ 7.60	SD1	0.80	1.90			▲ 5.00		
		▲ 1.01	AW8	0.45	0.45			▲ 5.00		
		▲ 2.88	AW9	0.60	0.60			▲ 8.00		
		▲ 0.72	AW9A	0.60	0.60			▲ 2.00		
		▲ 8.24	SD4	1.53	1.80			▲ 3.00		
		▲ 12.18	SD3	1.25	2.44			▲ 4.00		
		▲ 1.43	AW7B	1.50	0.95			▲ 1.00		
		2.28	A-08 2階東西面 廊下壁	1.27	0.90			2.00		
		7.42	A-08 2階北面 廊下壁	1.40	2.65			2.00		
		2.57		1.43	0.90			2.00		
		8.51		1.61	2.65			2.00		
		3.98		0.30	2.65			5.00		
		6.63		0.50	2.65			5.00		
		11.13		2.10	2.65			2.00		
		8.58		4.77	0.90			2.00		
		12.48		1.57	2.65			3.00		
		4.89		5.43	0.90			1.00		
		8.49		9.43	0.90			1.00		
		▲ 3.09	アルミハコ部開口	3.63	0.85			▲ 1.00		
		▲ 1.96		2.30	0.85			▲ 1.00		
		▲ 10.36	AW10	1.09	1.90			▲ 5.00		
		1.64	梁型	1.27	0.33			4.00		
		1.32		0.30	2.20			2.00		
		2.42		0.55	2.20			2.00		
		1.58		0.79	1.00			2.00		
		0.68		0.17	1.00			4.00		
		1.50		0.75	1.00			2.00		
		1.36		0.68	1.00			2.00		
		0.23		0.23	1.00			1.00		
				1.29	A-09 3階南面 廊下壁	0.28	2.30		2.00	

項目	単位	数量	計 算 式				定数	倍数
			コソト	Xm	Ym			
		22.11		1.89	2.34			5.00
		9.43		2.05	2.30			2.00
		2.76		0.30	2.30			4.00
		27.05		5.88	2.30			2.00
		2.53		0.55	2.30			2.00
		31.41		5.06	6.21			1.00
		0.48	笠木天端	1.38	0.35			1.00
		6.73		2.93	2.30			1.00
		9.36	玄関前	0.80	2.34			5.00
		8.19		0.70	2.34			5.00
		4.03	柱型	0.35	2.30			5.00
		8.05	カウンター部	0.35	2.30			10.00
		17.69	コモンスペース	2.76	3.21			2.00
		1.61		0.25	3.21			2.00
		3.80	柱型	0.55	2.30			3.00
		▲ 7.60	SD1	0.80	1.90			▲ 5.00
		▲ 1.01	AW8	0.45	0.45			▲ 5.00
		▲ 2.88	AW9	0.60	0.60			▲ 8.00
		▲ 0.72	AW9A	0.60	0.60			▲ 2.00
		▲ 13.73	SD4	1.53	1.80			▲ 5.00
		▲ 12.18	SD3	1.25	2.44			▲ 4.00
		▲ 1.43	AW7B	1.50	0.95			▲ 1.00
		2.28	A-09 3階東西面 廊下壁	1.27	0.90			2.00
		6.33	A-09 3階北面 廊下壁	0.55	2.30			5.00
		3.45		0.30	2.30			5.00
		6.44		1.40	2.30			2.00
		2.57		1.43	0.90			2.00
		7.38		1.61	2.30			2.00
		3.78		2.10	0.90			2.00
		8.58		4.77	0.90			2.00
		10.83		1.57	2.30			3.00
		4.89		5.43	0.90			1.00
		8.49		9.43	0.90			1.00
		4.58		2.18	1.05			2.00
		▲ 3.09	アルミベネ部開口	3.63	0.85			▲ 1.00
		▲ 1.96		2.30	0.85			▲ 1.00
		▲ 10.36	AW10	1.09	1.90			▲ 5.00
		0.17	梁型	0.58	0.30			1.00
		0.63		0.58	0.55			2.00
		2.58	A-11 2階廊下梁	1.27	0.34			6.00
		1.32		0.30	2.20			2.00
		2.42		0.55	2.20			2.00
		2.37		0.79	1.00			3.00
		0.68		0.17	1.00			4.00
		1.50		0.75	1.00			2.00
		1.36		0.68	1.00			2.00
		0.23		0.23	1.00			1.00
外部	水洗い工法	吹付タイル	m2	150.04				
	超汚染・超耐久型2液水性ふっ素樹脂塗料			25.58	階段（2箇所） A-19 壁	12.79	1.00	2.00
		階段室		34.32		17.16	1.00	2.00
				20.30		10.15	1.00	2.00
				19.24		9.62	1.00	2.00
				14.24	真ん中手摺	1.78	1.00	8.00
				23.46		2.93	1.00	8.00
				3.36		0.84	1.00	4.00
				6.10	3階手摺	2.18	1.40	2.00
外部	下地調整材C-2	リシン	m2	28.52				
	天井	外装薄塗材Si吹付		17.68	A-11 3階 パールコニー	4.16	0.85	5.00
		高圧水洗工法		10.84		3.94	0.55	5.00
外部	下地調整材C-2	リシン	m2	175.33				
	天井	外装薄塗材Si吹付		7.09	開放廊下 A-11 2階天井	7.09	1.00	1.00
		水洗工法		51.70		51.70	1.00	1.00
				7.09		7.09	1.00	1.00
				8.27	開放廊下 A-11 3階天井	8.27	1.00	1.00
				66.60		66.60	1.00	1.00
				8.27		8.27	1.00	1.00
				0.36	2階脆弱箇所②	0.30	0.30	4.00
				0.52	③	1.30	0.40	1.00
				0.18	④	0.30	0.60	1.00
				0.18	3階脆弱箇所④	0.90	0.20	1.00
				0.36	⑤	0.60	0.60	1.00
				2.30		2.30	1.00	1.00
				5.45	階段通路 A-11 1階	5.45	1.00	1.00
				5.54		5.54	1.00	1.00
				11.42	2階	5.71	1.00	2.00
					3階は階段室で測定			
外部	下地調整材C-2	リシン	m2	75.74				

項目	単位	数量	計 算 式				定数	倍数
			コmnt	Xm	Ym			
外装薄塗材Si吹付 階段室		16.53	A-19、A-09 1、2階階段室天井	2.76	1.50			4.00
水洗工法		5.97		1.81	1.65			2.00
		0.98		1.64	0.30			2.00
		5.28		1.38	1.92			2.00
		8.11		2.70	1.50			2.00
		1.48		0.21	3.53			2.00
		18.61	A-11 3階階段室天井	18.61	1.00			1.00
		18.78		18.78	1.00			1.00
天井 素地ごしらえB種	m2	67.47						
EP改修 ケイカル下地		3.27	A-11 1階 玄関前	1.09	1.00			3.00
		4.20		2.10	1.00			2.00
		2.26		1.13	1.00			2.00
		6.40	A-11	6.40	1.00			1.00
		21.18	A-11 1階 バルコニー	3.94	1.08			5.00
		21.18	A-11 2階 バルコニー	3.94	1.08			5.00
		8.98	3階コモンスペース上部	5.56	1.62			1.00
天井 素地ごしらえB種	m2	11.06						
外装薄塗材Si ケイカル下地		3.27	A-11 2階 玄関前	1.09	1.00			3.00
		2.26		1.13	1.00			2.00
		3.27	A-11 3階 玄関前	1.09	1.00			3.00
		2.26		1.13	1.00			2.00
外部 水洗い工法 巾木	m2	42.82						
		0.41	開放廊下 1階巾木 北面	1.62	0.13			2.00
		0.06		0.25	0.13			2.00
		0.39		1.55	0.13			2.00
		4.54		36.30	0.13			1.00
		0.21		0.55	0.13			3.00
		0.11		0.30	0.13			3.00
		1.86	屋外物置前	3.59	0.13			4.00
		0.38		1.45	0.13			2.00
		▲ 1.17	AD2	0.90	0.13			▲ 10.00
		0.55	南面	0.55	0.13			8.00
		0.50		0.80	0.13			5.00
		0.44		0.70	0.13			5.00
		0.70		0.35	0.13			16.00
		3.02		12.06	0.13			2.00
		0.25		0.98	0.13			2.00
		1.14		9.11	0.13			1.00
		0.01		0.10	0.13			1.00
		0.07		0.53	0.13			1.00
		0.08		0.60	0.13			1.00
		▲ 1.23	AD1	1.89	0.13			▲ 5.00
		▲ 0.55	AD3	0.85	0.13			▲ 5.00
		▲ 0.33	SD2	1.25	0.13			▲ 2.00
		▲ 0.33	SD3	1.25	0.13			▲ 2.00
		▲ 0.99	SD4	1.53	0.13			▲ 5.00
		1.11	開放廊下 2階巾木 北面	4.44	0.13			2.00
		0.19		0.30	0.13			5.00
		4.14		33.15	0.13			1.00
		0.19		0.50	0.13			3.00
		0.11	南面	0.42	0.13			2.00
		0.56		0.90	0.13			5.00
		0.50		0.80	0.13			5.00
		3.42		13.69	0.13			2.00
		0.70		0.35	0.13			16.00
		0.19		0.78	0.13			2.00
		1.27		10.15	0.13			1.00
		0.03		0.10	0.13			2.00
		▲ 0.52	SD1	0.80	0.13			▲ 5.00
		▲ 0.65	SD3	1.25	0.13			▲ 4.00
		▲ 0.99	SD4	1.53	0.13			▲ 5.00
		0.68	東西	2.72	0.13			2.00
		0.06	コモンスペース	0.25	0.13			2.00
		0.31		1.25	0.13			2.00
		1.11	開放廊下 3階巾木 北面	4.44	0.13			2.00
		0.19		0.30	0.13			5.00
		0.19		0.50	0.13			3.00
		4.14		33.15	0.13			1.00
		0.11	南面	0.42	0.13			2.00
		0.56		0.90	0.13			5.00
		0.50		0.80	0.13			5.00
		3.42		13.69	0.13			2.00
		0.70		0.35	0.13			16.00
		0.19		0.78	0.13			2.00
		0.66		5.06	0.13			1.00
		1.27		10.15	0.13			1.00
		▲ 0.52	SD1	0.80	0.13			▲ 5.00
		▲ 0.65	SD3A	1.25	0.13			▲ 4.00
		▲ 0.99	SD4	1.53	0.13			▲ 5.00
		5.62	A-19 階段巾木	0.54	1.30			8.00

	項 目	単位	数 量	計 算 式					
				コ ン ト	X _m	Y _m		定数	倍数
			4.37		0.42	1.30			8.00
			0.53	A-08 階段巾木	0.83	0.16			4.00
外部	水洗い工法	ハ [°] ルコニー	m2						
	床		17.68	ハ [°] ルコニー1階 床	4.16	0.85			5.00
			6.90		3.94	0.35			5.00
			17.68	ハ [°] ルコニー2階 床	4.16	0.85			5.00
			6.90		3.94	0.35			5.00
			17.68	ハ [°] ルコニー3階 床	4.16	0.85			5.00
			6.90		3.94	0.35			5.00
			2.16	ハ [°] ルコニー巾木 A-08、A-16	1.20	0.09			20.00
			3.55		3.94	0.09			10.00
外部	水洗い工法	開放廊下	m2						
	床	階段	5.25	A-07 階段 1F	1.25	2.10			2.00
		自転車置場	5.67		1.35	2.10			2.00
			9.95		3.53	1.41			2.00
			5.25	A-08 階段 2F	1.25	2.10			2.00
			5.67		1.35	2.10			2.00
			9.95		3.53	1.41			2.00
			88.14	開放廊下 1階床	88.14	1.00			1.00
			95.27	開放廊下 2階床	95.27	1.00			1.00
			82.63	開放廊下 3階床	82.63	1.00			1.00
			26.55	自転車置場 床	5.90	4.50			1.00
建築 名板	水洗い工法	建築名板	m2						
			0.24						
			0.24	建築名板	0.60	0.40			1.00
雑	MS-2	20×10	m						
	打継目地		506.51						
			6.56	A-07 外壁南面	3.28	1.00			2.00
			21.60		4.32	1.00			5.00
			15.92		7.96	1.00			2.00
			6.16		6.16	1.00			1.00
			7.06		7.06	1.00			1.00
			14.00		1.40	1.00			10.00
			15.80	A-07 外壁東西面	7.90	1.00			2.00
			8.77		4.39	1.00			2.00
			6.56	A-07 外壁北面	3.28	1.00			2.00
			44.90		44.90	1.00			1.00
			7.93	外壁 階段横	3.97	1.00			2.00
			3.24	1階 廊下北面	1.62	1.00			2.00
			0.50		0.25	1.00			2.00
			3.10		1.55	1.00			2.00
			36.30		36.30	1.00			1.00
			1.65		0.55	1.00			3.00
			0.90		0.30	1.00			3.00
			14.34	屋外物置前	3.59	1.00			4.00
			2.90		1.45	1.00			2.00
			▲ 9.00	AD2	0.90	1.00			▲ 10.00
			4.40	1階 廊下南面	0.55	1.00			8.00
			4.00		0.80	1.00			5.00
			3.50		0.70	1.00			5.00
			5.60		0.35	1.00			16.00
			24.12		12.06	1.00			2.00
			1.96		0.98	1.00			2.00
			9.11		9.11	1.00			1.00
			0.10		0.10	1.00			1.00
			0.53		0.53	1.00			1.00
			0.60		0.60	1.00			1.00
			▲ 9.45	AD1	1.89	1.00			▲ 5.00
			▲ 4.25	AD3	0.85	1.00			▲ 5.00
			▲ 2.50	SD2	1.25	1.00			▲ 2.00
			▲ 2.50	SD3	1.25	1.00			▲ 2.00
			▲ 7.63	SD4	1.53	1.00			▲ 5.00
			8.87	2階 廊下北面	4.44	1.00			2.00
			1.50		0.30	1.00			5.00
			33.15		33.15	1.00			1.00
			1.50		0.50	1.00			3.00
			0.84	2階 廊下南面	0.42	1.00			2.00
			4.50		0.90	1.00			5.00
			4.00		0.80	1.00			5.00
			27.38		13.69	1.00			2.00
			5.60		0.35	1.00			16.00
			1.55		0.78	1.00			2.00
			10.15		10.15	1.00			1.00
			0.20		0.10	1.00			2.00
			▲ 4.00	SD1	0.80	1.00			▲ 5.00
			▲ 5.00	SD3	1.25	1.00			▲ 4.00
			▲ 7.63	SD4	1.53	1.00			▲ 5.00
			5.43	2階 廊下東西	2.72	1.00			2.00
			0.50	コモンスペース	0.25	1.00			2.00
			2.50		1.25	1.00			2.00
			8.87	3階 廊下北面	4.44	1.00			2.00

	項 目	単位	数 量	計 算 式					
				コソト	Xm	Ym		定数	倍数
			1.50		0.30	1.00			5.00
			1.50		0.50	1.00			3.00
			33.15		33.15	1.00			1.00
			0.84	3階 廊下南面	0.42	1.00			2.00
			4.50		0.90	1.00			5.00
			4.00		0.80	1.00			5.00
			27.38		13.69	1.00			2.00
			5.60		0.35	1.00			16.00
			1.55		0.78	1.00			2.00
			5.06		5.06	1.00			1.00
			10.15		10.15	1.00			1.00
			▲ 4.00	SD1	0.80	1.00			▲ 5.00
			▲ 5.00	SD3A	1.25	1.00			▲ 4.00
			▲ 7.63	SD4	1.53	1.00			▲ 5.00
			34.00	A-19階段室巾木	4.25	1.00			8.00
			30.72		3.84	1.00			8.00
			26.50	柱際縦目地	2.65	1.00			10.00
手摺	DP塗	m	294.75	長手方向2段					
	素地ごしらえC種		25.86	1階西より	6.47	2.00			2.00
			8.06		2.02	2.00			2.00
			18.66		9.33	2.00			1.00
			4.64	2階西より	1.16	2.00			2.00
			5.32		1.33	2.00			2.00
			18.66		4.67	2.00			2.00
			10.66		5.33	2.00			1.00
			18.66		9.33	2.00			1.00
			4.64	3階西より	1.16	2.00			2.00
			5.32		1.33	2.00			2.00
			18.66		4.67	2.00			2.00
			10.66		5.33	2.00			1.00
			18.66		9.33	2.00			1.00
			5.29	コモン側	1.32	2.00			2.00
			1.12	1階支柱6.47m	0.16	1.00			7.00
			0.64	2.02m	0.16	1.00			4.00
			1.60	9.33m	0.16	1.00			10.00
			0.64	2、3階支柱1.16m	0.16	1.00			4.00
			0.64	1.33m	0.16	1.00			4.00
			3.20	4.665m	0.16	1.00			20.00
			1.92	5.33m	0.16	1.00			12.00
			3.20	9.33m	0.16	1.00			20.00
				長手方向5段、6段					
			45.84	階段 踊り場	1.91	6.00			4.00
			32.20		1.61	5.00			4.00
			30.00	支柱	1.50	5.00			4.00
鉄骨	DP塗	m2	41.24		単位質量kg/m	m		塗装係数	
梁	下地調整 (RB種)		16.70	梁H-200*100*5.5*8	20.90	3.33		0.03	8.00
	素地ごしらえ (B種)		2.90	梁H-200*100*5.5*8	20.90	4.63		0.03	1.00
			9.41	梁H-150*75*5*7	14.00	1.40		0.04	12.00
			12.23	C-75*45*15*2.3	3.25	1.40		0.11	24.00
3	建具改修工事								
建具	ガラス清掃	片面	350.38						
			27.00	AW-1	2.700	2.000			5.00
			51.81	AW-2、2A	2.700	1.919			10.00
			90.24	AW-3、3A	3.135	1.919			15.00
			29.33	AW-4、4A	1.700	1.150			15.00
			14.66	AW-5、5A	0.850	1.150			15.00
			8.42	AW-6、6A	0.600	1.169			12.00
			12.24	AW-7、7A	1.700	1.200			6.00
			4.28	AW-7B	1.500	0.950			3.00
			4.05	AW-8	0.450	0.600			15.00
			8.64	AW-9、9A	0.600	0.600			24.00
			26.92	AW-10	1.090	1.900			13.00
		(両面)	10.18	AW-11	0.707	1.800			8.00
			2.00	三角	0.250	1.000			8.00
			6.58	AW-12	1.370	0.800			6.00
			54.03	CW1	3.450	7.830			2.00
建具	MS-2	15 x 10	1,366.69						
	建具廻りシーリング撤去	新設	40.50	AW-1	2.700			3.00	5.00
			20.00		2.000			2.00	5.00
			81.00	AW-2、2A	2.700			3.00	10.00
			38.38		1.919			2.00	10.00
			141.08	AW3、3A	3.135			3.00	15.00
			57.57		1.919			2.00	15.00

建築10

産廃1